

**NOTICE OF HAZARD CLEARANCE &
CLEARANCE REPORT PROTOTYPE**

URBAN RENOVATION CONSULTANTS, INC
P.O. Box 799
Beaufort, NC 28516
252-728-6924

Firm Certification Number: NC 12345

CLEARANCE REPORT

General Information

Date of Inspection:	September 15, 1999
Clearance Inspector:	R. M. Santucci
Certification Number:	NC 12345
Property address:	1135 Trout Avenue Portland, OR 97214
Client Name:	Community Development Inc.
Client Address:	2136 S.E. Salmon Portland, OR
Laboratory:	Hometest.com
Address:	176 Smallwood Village Center Waldorf, MD 20602
Telephone Number:	1-800-604-1995
NLLAP Number:	MD 9999999

THIS UNIT PASSES FAILS CLEARANCE

SIGNATURE: R. M. Santucci

DATE: SEPTEMBER 15, 1999

Lessee's Acknowledgement

The Lessee, _____, has received a copy of this Lead Hazard Clearance Notice.

Signature of Lessee _____

Date _____

DUST SAMPLING RESULTS FORM

Date of Collection: September 15, 1999

Sample	Location	Surface	Dimensions of Sample Area	Lead $\mu\text{g}/\text{ft}^2$	Above/ Below Standard
2136-1	Upstairs small bedroom #12	Window (C-2)	4" x 18"	110	Below
2136-2	Upstairs small bedroom #12	Floor under C-1 window	12" x 12"	25	Below
2136-3	Upstairs bedroom #15	Window (C-1)	4" x 18"	95	Below
2136-4	Staircase/ Landing #10	Floor	12" x 12"	40	Below
2136-5	Kitchen #7	Floor under A-1 window	12" x 12"	ND	Below
2136-6	Kitchen #7	Window (A-1) sill	4" x 18"	160	Below
2136-7	1 st Foyer	Floor	12" x 12"	30	Below
2136-8	Blank	Blank	12" x 12"	ND	Pass

Contact person for more information about the clearance report:

Printed name: R.M. Santucci
 Signature: *R. M. Santucci*
 Date: September 21, 1999
 Organization: URC, Inc.
 Street: 1703 B Front Street
 City & State: Beaufort, N.C.
 Zip: 28516
 Phone #: 252-728-6924

Person who prepared this notice:

Printed name: R.M. Santucci
 Signature: *R. M. Santucci*
 Date: September 21, 1999
 Organization: URC, Inc.
 Street: 1703 B Front Street
 City & State: Beaufort, N.C.
 Zip: 28516
 Phone #: 252-728-6924